



SIDE VIEW

REAR VIEW

AMENDMENTS		
No.	DESCRIPTION	APPROVED & DATE
1	EMBEDMENT DEPTH & NOTE 6 AMENDED, NOTE 12 ADDED.	<i>[Signature]</i> 24/5/16

- NOTES**
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH SPECIFICATION 712.
 - FOR GENERAL LAYOUT SEE DRG No's. 200431-0104 & 200431-0105.
 - FOR SIGN AND POST FABRICATION DETAILS SEE DRG No's. 200431-0085 TO 200431-0092.
 - ACTUAL STIFFENER LAYOUT MAY VARY FROM LAYOUT SHOWN. CONTRACTOR TO USE SAME FIXINGS & SIMILAR METHODOLOGY TO SECURE CABLES TO STIFFENERS.
 - FOR FOOTING DETAILS SEE DRG No. 201431-0016.
 - FOR WIRING DETAILS SEE DRG No. 201531-0060.
 - ALL FASTENINGS AND FIXTURES SHALL BE GRADE 316 STAINLESS.
 - AT LEAST 1m OF SLACK OF THE OUTGOING CABLE SHALL BE STORED IN THE POLE.
 - OUTGOING CABLES SHALL BE SUITABLY FIXED WITHIN THE PIT TO REDUCE THE RISK OF PULLING ON THE ENCLOSURE WHEN THE SLACK HAS BEEN TAKEN UP.
 - FOR TERMINATION PIT SEE SPECIFICATION 712 AND DRG No. 200431-0128.
 - FOR TYPICAL ELECTRICAL CONSTRUCTION DETAILS USING CHS POSTS SEE DRG No. 200431-0100.
 - ALL WORK IS TO BE COMPLETED AND MAINTAINED UNDER RAILWAY PROVIDER'S SUPERVISION OR INSTRUCTION.

Government of Western Australia

 PLANNING AND TECHNICAL SERVICES

 ROAD AND TRAFFIC ENGINEERING

 WATERLOO CRESCENT EAST PERTH 6004

 Telephone (08) 9323 4111 Fax (08) 9323 4449

FILE NUMBER	67-08-4F
DESIGNED / DRAWN	D.LANDMARK/J.VOKE 2.7.14
VERIFIED	S.FALL 7.7.14
APPROVED	R.GROVE 8.7.14

STANDARD DRAWING
 ADVANCE WARNING FLASHING SIGNS
 TYPICAL ELECTRICAL CONSTRUCTION
 USING ALUMINIUM FRANGIBLE POSTS

LOCAL AUTHORITY
 DRAWING NUMBER AMENDMENT
 201431-0015-1

SCALE N.T.S.
 MICROFILM DATE
 A 3